

GOVT. OF JAMMU AND KASHMIR
JAL SHAKTI DEPARTMENT WATER QUALITY MONITORING
DISTRICT WATER TESTING LABORATORY BUMZOO
ANANTNAG



Test Report

ULR No:

Source:	Lidder Nallah.		
Client Ref No:	—		
W/S/S:	Anantnag	Status:	Treated
Habitation/ Collection at (Village):	G.D. Goenka Public	Block:	ANG.
Report No:	June 24/01 School	Report Issue Date:	24/06/24
Laboratory reference:	D.W.T.L Anantnag.		
Sample Description:	5 ltrs. in Plastic Can	Date of Receipt:	21/06/24.
Test Start Date:	21/06/24.	Test End Date:	24/06/24.
Test Condition:	24°C 53%		

Sample Collected By:	School employee
Sample ID:	—
Sample is not withdrawn by the laboratory	

Sr. No	Parameters	Units	Results	Permissible limits	Desirable Limits
Organoleptic & Physical Parameters					
1	Colour	Hazen units	5	5	15
2	Odour	-	Agreeable	Agreeable	Agreeable
3	pH at 25°C	-	7.3	6.5-8.5	-
4	Taste	-	Agreeable	Agreeable	Agreeable
5	Turbidity	NTU	1.50	1	5
6	Total dissolved solids	mg/l	116	500	2000
General Parameters concerning substances undesirable in excessive amounts					
7	Total Hardness	mg/l	66	200	600
8	Total Alkalinity	mg/l	44	200	600
9	Chloride	mg/l	6.99	250	1000
10	Calcium	mg/l	24	75	200
11	Magnesium	mg/l	10.2	30	100
12	Residual Chlorine	mg/l	0.0	0.2	1.0
13	Iron	mg/l	0.0	1.0	No Relaxation
14	E. Coli		Absent	No Relaxation	No Relaxation

[Signature]
Lab Assistant

[Signature]
24/06/24
Chemist
DWT/BA

- Note:
- The test report and result relate to the specimen/ sample (s) of the material as delivered /received and tested in the laboratory.
 - This test report shall not be reproduced in part, without the permission of this laboratory.
 - Any correction invalidates this test reports.
 - WQL Lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/legal liability arising out of any errors or omissions. Refer to terms & Conditions of reports overleaf.



[Signature]
CHAIRMAN
G.D. GOENKA PUBLIC SCHOOL
ANANTNAG (J&K)